



NOTES:

1. ALL PLASTIC PIPE TO BE INSTALLED ACCORDING TO THESE DETAILS UNLESS OTHERWISE NOTED OR DETAILED.
2. THE PORTLAND CEMENT CONCRETE USED FOR THRUST BLOCKS SHALL BE CLASS B CONCRETE (5SACKS) @ 176kg/sq.cm(2500psi) min.
3. ALL ANCHOR RODS SHALL BE GALVANIZED STEEL, MINIMUM 13mm(1/2") DIAMETER, WRAPPED AROUND PIPE.
4. SIZE OF THRUST BLOCKS SHALL BE SPECIFIED ON PLANS.
5. THRUST BLOCKS SHALL BE USED FOR PLASTIC PIPES WITH 76mm(3") DIAMETER OR LARGER.
6. FLOW DIRECTION INDICATED BY →
7. ALL VIEWS ARE PLAN VIEW UNLESS OTHERWISE SHOWN.

All units are in metric
Non-metric units are in brackets

ACAD FILENAME: PIPEBLOC

CITY OF MENLO PARK STANDARD DETAILS



NO.	REVISIONS	DATE

**IRRIGATION SYSTEM
THRUST BLOCK
FOR PLASTIC PIPE**

APPROVED

Y. A. Owens
for Director of Engineering Services R.C.E. No. 40998

DRAWN CHECKED NN DATE 1-1-97 SCALE NTS SHEET 1 OF 1

STD. DETAIL No.: **LS-2**