

## Murphy, Justin I C

---

**From:** Bill Kitajima [bkitajima@westbaysanitary.org]  
**Sent:** Thursday, May 26, 2011 3:47 PM  
**To:** Murphy, Justin I C  
**Cc:** Phil Scott  
**Subject:** Facebook EIR

Justin;

The District has reviewed the Notice of Preparation from the City of Menlo Park for the Menlo Park Facebook Campus project and have the following comments:

- Pursuant to our meeting the District has not heard from Facebook regarding discharge or improvement needs.
- The District currently does not have sanitary sewerlines that can serve the proposed west campus and would require the applicant to extend the sanitary sewer system to the District's approval and requirements. The proposed sewer improvement will require the issuance and acceptance of a Class 3 sewer permit for the proposed main sewer extension from the District and the applicant must obtain separate Class 2 sewer permit(s) for the proposed improvements after the main sewer extension is accepted by the District Board.
- The proposed upgrade to the east campus pumping system and the proposed west campus may require upgrades to the existing sanitary sewer gravity mains between the forcemain connection point to the District's main pump station at Marsh Road and BayFront.
- The District, along with the Cities of Belmont, San Carlos, and Redwood City comprise the Joint Powers Agency of SBSA. SBSA operates the pump stations that are located at the terminus of each member's collection system, including the Menlo Park Pump Station located at the northern end of Marsh Road.
- Without the applicant's discharge requirements, the District is unable to determine the impact on sewer service to the area of the proposed development. Once determined the District will determine whether the proposed improvement would impact any sewer system conveyance and treatment limitations.

If you have any questions feel free to call me at 650-321-0384.

Bill Kitajima  
West Bay Sanitary District